



# CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Certificate No.: CE220303007551

**Product**

Moulded Case Circuit Breaker

**Applicant**

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

**Type/Model**

TGM3-63L, TGM3-63M, TeM5-63L, TeM5-63M;

**Technical data**

Uimp:8kV; Ui: 800V;  
Ue:AC380V/400V/415V;In:10A,15A,16A,20A,25A,30A,32A,40A,50A,60A,63A;Type of over-current release: Thermal-magnetic, Electro-magnetic; Type L: Ics:18kA,Icu:25kA;Type M: Ics:25kA,Icu:35kA; Selectivity category: A; 3P,3P+N(3 protected poles with an uninterrupted neutral pole),4P; 3P 4P: suitable for isolation; 3P+N: not suitable for isolation; Matching auxiliary contact:1NO1NC,2NO2NC,4NO4NC, Uimp:4kV; Ui:500V, Ith:3A,AC-15:380V/0.4A, DC-13:220V/0.15A; Matching alarm contact: NO1NC,2NO2NC,4NO4NC, Uimp:4kV;Ui:500V,Ith:3A,AC-15: 380V/0.4A,DC-13:220V/0.15A;Electronic accessory complying with annex N:Undervoltage release: Uimp:4kV;Ui:500V Us: AC(220/230/240)V, AC(380/400/415)V, 50HZ;Motor-operator: Uimp:4kV;Ui:500V; Us: AC(220/230/240)V,AC(380/400/415)V, 50HZ; Shunt release with prepayment: Uimp:4kV;Ui:500V Us:AC220V,AC380V, 50HZ

This is to certify that, on the basis of the tests undertaken as per Report No. (2024)FQIIDQCE-0445, the submitted sample(s) of the above item complies with:

**EN 60947-2:2017/A1:2020;EN 60947-2:2017**

and fulfills testing requirements of the European Directive:

**2014/35/EU**

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

**Valid from: Dec.30,2024**

**Valid until: Dec.29,2027**

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGNATURE:

谢肇煦



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE